

### Registration Details

Print

SPAN Listing : 300-10/641/B/W-4  
No.

Manufacturer : CONTROLMATIK ABW D.O.O FAJFARJEVA 15, 1230 DOMZALE,  
SLOVENIA

Principal : GLOBAL SOLUTIONS (BULGARIA) PLLC SUITE 28TH, 7TH FLOOR  
OFFICE BUILDING FINA 5 SOFIA BULGARIA

Category B (WATER)

Group : WATER TREATMENT EQUIPMENT

Product : DISINFECTANT

Type : CHLORINE DISINFECTANT

Sub-type : NA

Details :  
Information

Model	Series	Description
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 3100 C	EVAPORATORS SERIES M 3100 C ARE DESIGNED TO HEAT LIQUID CHLORINE TAKEN FROM STORAGE CONTAINERS AND TURN IT TO GAS CHLORINE.
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 400 & M 440	THE AUTOMATIC SWITCHOVER SYSTEM IS COMPLETELY VACUUM OPERATED DEVICE AND AUTOMATICALLY SWITCHES CHLORINE FEED FROM AN EMPTY CHLORINE SOURCE TO A FULL CHLORINE SOURCE, WITHOUT MANUAL RESET - CAPACITY UP TO 10kg/h & UP TO 120kg/h.
SAFETY EQUIPMENT	M 2103 C	THE M 2103 C SERIES CONTROLMATIK ABW CHLORINE GAS DETECTION SENSOR IS DESIGNED TO DETECT AND INDICATE CHLORINE CONCENTRATION IN THE AIR AND TO PROVIDE SAFETY IN STORAGE AREAS AND IN PLACES

Model	Series	Description
		WHERE THE GASEOUS CHLORINE AND SODIUM HYPOCHLORITE ARE DOSED.
SAFETY EQUIPMENT	M 4510 C	THE 4510 C SERIES CONTROLMATIK ABW DETECTION UNIT IS ASSEMBLED AS SEPARATE SIGNAL EVALUATION UNIT WITH DISPLAY, UNIT WITH TWO ADJUSTABLE ALARMS AND FAULT ALARMS, POWER SUPPLY UNIT AND SEPARATE DETECTION CELL-PROBE. - CHLORINE GAS LEAK DETECTOR.

Brands : CONTROLMATIK

Standard : MANUFACTURER SPECIFICATION

: CONTROLMATIK ABW

Certificate body  
& Certificate  
No

Certification  
Scope

Valid Until : 2021/12/31

*This report is computer generated and no signature is required. SPAN will not responsible for any misuse of this report. Please contact SPAN at 03-83179333/334/335 for verification of any information established in this report.*



Registration Details

Print

SPAN Listing : 300-10/641/B/W-4  
No.

Manufacturer : CONTROLMATIK ABW D.O.O FAJFARJEVA 15, 1230 DOMZALE, SLOVENIA

Principal : GLOBAL SOLUTIONS (BULGARIA) PLLC SUITE 28TH, 7TH FLOOR OFFICE BUILDING FINA 5

Category B (WATER)

Group : WATER TREATMENT EQUIPMENT

Product : DISINFECTANT

Type : CHLORINE DISINFECTANT

Sub-type : NA

Details Information :

Model	Series	Description
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 20 C	VACUUM REGULATORS ARE DESIGNED TO FEED GAS CHLORINE AND WITH MINOR ALTERATIONS ALSO FOR OTHER GASES, WORKING ON THE INDIRECT VACUUM PRINCIPLE - CAPACITY UP TO 15kg/h
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 200 C	M 200 C GAS FLOWMETERS ARE GAS FLOW INDICATORS APPLIED IN A GAS CHLORINATION SYSTEM TO REGULATE THE FLOW.
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 300C	EJECTORS IS A MECHANICAL DEVICE THAT GENERATES THE VACUUM NECESSARY FOR OPERATION OF THE FEED SYSTEM - CAPACITY UP TO 15 kg/h.
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 3100 C	EVAPORATORS SERIES M 3100 C ARE DESIGNED TO HEAT LIQUID CHLORINE TAKEN FROM STORAGE CONTAINERS AND TURN IT TO GAS CHLORINE.

<b>Model</b>	<b>Series</b>	<b>Description</b>
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 340 C & M 350 C	THE HIGH CAPACITY EJECTORS SERIES M340C AND M350C ARE DESIGNED TO FEED LARGER AMOUNT OF GAS CHLORINE INTO THE WATER - CAPACITY UP TO 200kg/h.
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 3603 C	AUTOMATIC CHLORINATOR SEIES M3603C IS A HEAVY DUTY FEED UNIT INTENDED FOR ACCURATE MANUAL OR AUTOMATIC FEED OF CHLORINE GAS INTO WATER. IT IS DESIGNED TO BE CONTROLLED THROUGH 4-20mA CURRENT SIGNAL OR ModBUS COMMUNICATION.
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 3610 C	AUTOMATIC CHLORINATOR SEIES M3610C IS A HEAVY DUTY FEED UNIT INTENDED FOR ACCURATE MANUAL OR AUTOMATIC FEED OF CHLORINE GAS INTO WATER. IT IS DESIGNED TO BE CONTROLLED FROM CONTROLLER (AUTOMATIC CONTROL) OR IN CASE OF NEED IT CAN SIMPLY BE SWITCHED TO MANUAL CONTROL.
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 40 C	VACUUM REGULATORS M 40 C ARE DESIGNED TO FEED LARGER AMOUNT OF GAS CHLORINE AND WITH MINOR ALTERATIONS ALSO FOR OTHER GASES, WORKING ON THE INDIRECT VACUUM PRINCIPLE - CAPACITY UP TO 40kg/h
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 400 & M 440	THE AUTOMATIC SWITCHOVER SYSTEM IS COMPLETELY VACUUM OPERATED DEVICE AND AUTOMATICALLY SWITCHES CHLORINE FEED FROM AN EMPTY CHLORINE SOURCE TO A FULL CHLORINE SOURCE, WITHOUT MANUAL RESET - CAPACITY UP TO 10kg/h & UP TO 120kg/h.
DOSING EQUIPMENT FOR AGRESSIVE GASES	M 50 C	VACUUM REGULATORS SERIES M 50 C FUNCTION IN THE SAME WAY AS M 20 C VACUUM REGULATORS, WITH THE ONLY DIFFERENT THAT THEY ARE DESIGNED TO FEED LARGER AMOUNTS OF GAS. - CAPACITY UP TO 200kg/h

Model	Series	Description
DOSING EQUIPMENT FOR AGRESSIVE GASES	MR 520C, MR540C & MR 550C	FLOOR MOUNTED CHLORINATOR SERIES MR500C IS USED FOR ACCURATE FEED OF GAS CHLORINE, SULPHUR DIOXIDE AND OTHER GASES IN WATER SUPPLIES, WASTE WATER TREATMENT PLANTS AND INDUSTRY.
SAFETY EQUIPMENT	M 2103 C	THE M 2103 C SERIES CONTROLMATIK ABW CHLORINE GAS DETECTION SENSOR IS DESIGNED TO DETECT AND INDICATE CHLORINE CONCENTRATION IN THE AIR AND TO PROVIDE SAFETY IN STORAGE AREAS AND IN PLACES WHERE THE GASEOUS CHLORINE AND SODIUM HYPOCHLORITE ARE DOSED.
SAFETY EQUIPMENT	M 4510 C	THE 4510 C SERIES CONTROLMATIK ABW DETECTION UNIT IS ASSEMBLED AS SEPARATE SIGNAL EVALUATION UNIT WITH DISPLAY, UNIT WITH TWO ADJUSTABLE ALARMS AND FAULT ALARMS, POWER SUPPLY UNIT AND SEPARATE DETECTION CELL-PROBE. - CHLORINE GAS LEAK DETECTOR.

Brands : CONTROLMATIK

Standard : MANUFACTURER SPECIFICATION

: CONTROLMATIK ABW

Certificate  
body &  
Certificate No

:  
Certification  
Scope

Valid Until : 2022/03/31

*This report is computer generated and no signature is required. SPAN will not responsible for any misuse of this report. Please contact SPAN at 03-83179333/334/335 for verification of any information established in this report.*